



ELECTRICAL

Hazard		Satisfactory	Needs Attention	Not Applicable	Target Date for Completion	Date Completed
1	Are your workplace electricians familiar with the Cal/OSHA Electrical Safety Orders?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
2	Do you specify compliance with Cal/OSHA for all contract electrical work?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
3	Are all employees required to report as soon as practicable any obvious hazard to life or property observed in connection with electrical equipment or lines?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
4	Are all employees instructed to make preliminary inspections and/or appropriate tests to determine what conditions exist before starting work on electrical equipment or lines?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
5	When electrical equipment or lines are to be serviced, maintained or adjusted, are necessary switches opened, locked-out and tagged whenever possible?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
6	Are portable electrical tools and equipment grounded or of the double insulated type?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
7	Are electrical appliances such as vacuum cleaners, polishers, vending machines, etc., grounded?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
8	Do extension cords being used have a grounding conductor?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
9	Are multiple plug adaptors prohibited?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
10	Are ground-fault circuit interrupters installed on each temporary 15 or 20 ampere, 120 volt AC circuit at construction, demolition, modification, alteration or excavation sites?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
11	Do suitable disconnecting switches or plug connectors at the junction with permanent wiring protect all temporary circuits?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
12	Are all electrical raceways and enclosures securely fastened in place?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
13		<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
14		<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
15		<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		

Name

Date

Actions Taken to Correct Items Checked as "Needs Attention"

Hazard #	
Hazard #	
Hazard #	
Hazard #	
Hazard #	