



# ELEVATED SURFACES

Hazard		Satisfactory	Needs Attention	Not Applicable	Target Date for Completion	Date Completed
		<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
1	Are signs posted, when appropriate, showing the elevated surface load capacity?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
2	Are surfaces elevated more than 30 inches above the floor or ground provided with standard guardrails?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
3	Are all elevated surfaces (beneath which people or machinery could be exposed to falling objects) provided with standard 4-inch toe boards?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
4	Is a permanent means of access and egress provided to elevated storage and work surfaces?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
5	Is headroom provided where necessary?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
6	Is material on elevated surfaces piled, stacked or racked in a manner to prevent it from tipping, falling, collapsing, rolling or spreading?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
7	Are dock boards or bridge plates used when transferring materials between docks and trucks or rail cars?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
8		<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
9		<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
10		<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		

\_\_\_\_\_ Name

\_\_\_\_\_ Date

## Actions Taken to Correct Items Checked as "Needs Attention"

Hazard #	
Hazard #	
Hazard #	
Hazard #	
Hazard #	