



STAIRS and STAIRWAYS

Hazard		Satisfactory	Needs Attention	Not Applicable	Target Date for Completion	Date Completed
		<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
1	Are standard stair rails or handrails on all stairways having four or more risers?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
2	Are all stairways at least 22 inches wide?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
3	Do stairs have at least a 6' 6" overhead clearance?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
4	Do stairs angle no more than 50 and no less than 30 degrees?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
5	Are stairs of hollow-pan type treads and landings filled to nosing level with solid material?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
6	Are step risers on stairs uniform from top to bottom, with no riser spacing greater than 7-1/2 inches?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
7	Are steps on stairs and stairways designed or provided with a surface that renders them slip resistant?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
8	Are stairway handrails located between 30 and 34 inches above the leading edge of stair treads?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
9	Do stairway handrails have at least 1-1/2 inches of clearance between the handrails and the wall or surface they are mounted on?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
10	Are stairway handrails capable of withstanding a load of 200 pounds, applied in any direction?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
11	Where stairs or stairways exit directly into any area where vehicles may be operated, are adequate barriers and warnings provided to prevent employees stepping into the path of traffic?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
12	Do stairway landings have a dimension measured in the direction of travel, at least equal to the width of the stairway?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
13	Is the vertical distance between stairway landings limited to 12 feet or less?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
14	Is a stairway provided to the roof of each building four or more stories in height, provided the roof slope is 4:12 or less?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
15		<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
16		<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
17		<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		

_____ Name

_____ Date

Actions Taken to Correct Items Checked as "Needs Attention"

Hazard #	
Hazard #	
Hazard #	
Hazard #	
Hazard #	